

ADDENDA
TO ALL BIDDERS OF THE
2020 BENSON AVENUE WATER TANK INTERIOR PAINTING PROJECT
FOR THE
CITY OF MARGATE CITY
ATLANTIC COUNTY, NEW JERSEY

ADDENDUM NO. 1

You are hereby notified in accordance with Section 1.04 entitled “Addenda, Bid Specification Challenges and Interpretations” of the Information for Bidders of the above captioned project that the following has been issued to clarify the meaning of the plans and specifications and that the conditions and specifications set forth in said addenda are to be original contract documents.

I. Bid Opening Date

From: November 12, 2020 at 11:00 A.M.

To: November 13, 2020 at 11:00 A.M.

II. Clarifications

- a. An ISO 9001 certification in lieu of a QP 1 certification is acceptable.
- b. There is no lead paint in the tank.
- c. Two stripe coats are required on the welded seams in the wet interior area of the tank.
- d. It is anticipated that the contractor will mobilize on the project at the end of November 2020 or the beginning of December 2020.

THIS ADDENDUM MUST BE RETURNED WITH ALL BIDS. FAILURE TO RETURN THIS SIGNED RECEIPT WITH THE CONTRACT FORMS MAY RESULT IN A NON-RESPONSIVE BID.

I ACKNOWLEDGE RECEIPT OF THIS ADDENDUM:

Signature

Company

Date